

RESULTADOS DE LOS POZOS DEL SIMAS MONCLOVA Y FRONTERA 1er Semestre 2023

	SECTOR ORIENTE												
D	pH	TURBIDEZ	Cl	DUREZA TOT.	Mn	Fe	NO2-N	NO3-N	SO4	N2-NH3	Pb	As	Cd
	6.8	<0.5	70.82	772.74	<0.05	<0.1	<0.01	0.65	429.60	<0.3	<0.0025	<0.005	<0.00
	7.2	<0.5	82.31	1106.64	<0.05	<0.1	<0.01	0.46	656.75	<0.3	<0.0025	<0.005	<0.00
	7.1	<0.5	109.11	992.16	<0.05	<0.1	<0.01	0.72	815.50	<0.3	<0.0025	<0.005	<0.00
	7.0	<0.5	94.75	1030.32	0.00	<0.1	<0.01	0.67	730.00	<0.3	<0.0025	<0.005	<0.00
	7.2	<0.5	110.07	1128.72	<0.05	<0.1	<0.01	0.22	671.25	<0.3	<0.0025	<0.005	<0.00
	7.0	<0.5	99.09	904.32	<0.05	<0.1	<0.01	0.45	560.75	<0.3	<0.0025	<0.005	<0.00
	6.9	<0.5	100.50	1011.24	<0.05	<0.1	<0.01	0.48	676.25	<0.3	<0.0025	<0.005	<0.00
embre	7.2	<0.5	244.07	1640.88	<0.05	<0.1	<0.01	11.28	744.75	<0.3	<0.0025	<0.005	<0.00
s	6.9	<0.5	89.97	1039.86	<0.05	<0.1	<0.01	0.24	781.25	<0.3	<0.0025	<0.005	<0.00
	6.9	<0.5	101.45	1087.56	<0.05	<0.1	<0.01	0.29	605.50	<0.3	<0.0025	<0.005	<0.00
dio	7.02	#DIV/0!	110.21	1071.44	0.00	#DIV/0!	#DIV/0!	1.55	667.16	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
no	7.20	0.00	244.07	1640.88	0.00	0.00	0.000	11.28	815.50	0.00	0.00	0.00	0.00
o	6.80	0.00	70.82	772.74	0.00	0.00	0.000	0.22	429.60	0.00	0.00	0.00	0.00
	SECTOR SUR												
D	pH	TURBIDEZ	Cl	DUREZA TOT.	Mn	Fe	NO2-N	NO3-N	SO4	N2-NH3	Pb	As	Cd
	7.0	<0.5	48.33	868.14	<0.05	<0.1	<0.01	0.71	468.60	<0.3	<0.0025	<0.005	<0.00
	6.9	<0.5	49.29	992.16	<0.05	<0.1	<0.01	0.60	573.50	<0.3	<0.0025	<0.005	<0.00
	6.9	<0.5	52.16	868.14	<0.05	<0.1	<0.01	0.46	446.50	<0.3	<0.0025	<0.005	<0.00
	7.0	<0.5	37.8	829.98	<0.05	<0.1	<0.01	0.55	463.75	<0.3	<0.0025	<0.005	<0.00
	7.1	<0.5	179.46	801.36	<0.05	<0.1	<0.01	4.29	250.00	<0.3	<0.0025	<0.005	<0.00
dio	6.95	#DIV/0!	46.90	889.61	#DIV/0!	#DIV/0!	#DIV/0!	0.58	488.09	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
no	7.00	0.00	52.16	992.16	0.00	0.00	0.00	0.71	573.50	0.00	0.00	0.00	0.00
o	6.90	0.00	37.80	829.98	0.00	0.00	0.00	0.46	446.50	0.00	0.00	0.00	0.00
	SECTOR POZUELOS												
D	pH	TURBIDEZ	Cl	DUREZA TOT.	Mn	Fe	NO2-N	NO3-N	SO4	N2-NH3	Pb	As	Cd
	7.4	<0.5	17.70	385.41	<0.05	<0.1	<0.01	1.61	106.30	<0.3	<0.0025	<0.005	<0.00
A	6.9	<0.5	35.41	629.64	<0.05	<0.1	<0.01	2.40	264.60	<0.3	<0.0025	<0.005	<0.00
B	6.8	<0.5	24.40	591.48	<0.05	<0.1	<0.01	3.44	28.42	<0.3	<0.0025	<0.005	<0.00
	7.2	<0.5	7.17	354.88	<0.05	<0.1	<0.01	1.33	41.00	<0.3	<0.0025	<0.005	<0.00
A	7.0	<0.5	42.73	649.98	<0.05	<0.1	<0.01	1.55	386.20	<0.3	<0.0025	<0.005	<0.00
B	7.0	<0.5	25.84	677.34	<0.05	<0.1	<0.01	2.83	343.60	<0.3	<0.0025	<0.005	<0.00
B	7.2	<0.5	38.28	610.56	<0.05	<0.1	<0.01	1.97	331.80	<0.3	<0.0025	<0.005	<0.00
H	7.2	<0.5	25.84	581.94	<0.05	<0.1	<0.01	4.30	298.60	<0.3	<0.0025	<0.005	<0.00
S	6.9	<0.5	37.32	610.56	<0.05	<0.1	<0.01	2.61	412.25	<0.3	<0.0025	<0.005	<0.00
	7.0	<0.5	3.82	248.04	<0.05	<0.1	<0.01	1.71	28.22	<0.3	<0.0025	<0.005	<0.00
	7.0	<0.5	6.70	305.28	<0.05	<0.1	<0.01	0.85	19.42	<0.3	<0.0025	<0.005	<0.00
	7.4	<0.5	4.06	270.93	<0.05	<0.1	<0.01	1.99	22.36	<0.3	<0.0025	<0.005	<0.00
	7.3	<0.5	7.65	255.67	<0.05	<0.1	<0.01	0.84	295.90	<0.3	<0.0025	<0.005	<0.00
	7.2	<0.5	5.98	297.64	<0.05	<0.1	<0.01	1.00	41.20	<0.3	<0.0025	<0.005	<0.00
dio	7.11	#DIV/0!	20.21	462.10	#DIV/0!	#DIV/0!	#DIV/0!	2.03	187.13	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
no	7.40	0.00	42.73	677.34	0.00	0.00	0.00	4.30	412.25	0.00	0.00	0.00	0.00
o	6.80	0.00	3.82	248.04	0.00	0.00	0.00	0.84	19.42	0.00	0.00	0.00	0.00